产品认证证书

证书编号：CQC20130103076629 65

申请人名称及地址

上海西门子线路保护系统有限公司

上海市金山工业区时代大道 2395 号

制造商名称及地址

Siemens AG Low Voltage

Siemensstrasse 10, 93055 Regensburg, Germany

生产企业名称及地址

上海西门子线路保护系统有限公司(V025991)

上海市金山工业区时代大道 2395 号

产品名称和系列、规格、型号

电子式漏电模块

5SM9...-0KK, 5SM9...-0KN, 5SM9...-6KK, 5SM9...-6KN, 5SM9...-6KK01;详见参数附件

产品标准和技术要求

GB/T16917.1-2014;GB/T16917.22-2008

认证模式

型式试验+初始工厂检查+获证后监督

上述产品符合 CQC11-462143-2019 认证规则的要求，特发此证。

发证日期：2020 年 07 月 10 日　　有效期至：2023 年 11 月 15 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

主任：

中国质量认证中心

中国．北京．南四环西路 188 号 9 区 100070

http://www.cqc.com.cn

C 0261760

PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2013010307662965

NAME AND ADDRESS OF THE APPLICANT

Siemens Circuit Protection Systems Ltd.,Shanghai
2395 Shidai Avenue, Jinshan Industrial Zone, Jinshan District201506, Shanghai, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Siemens AG Low Voltage
Siemensstrasse 10,93055 Regensburg, Germany

NAME AND ADDRESS OF THE FACTORY

Siemens Circuit Protection Systems Ltd.,Shanghai (V025991)
2395 Shidai Avenue, Jinshan Industrial Zone, Jinshan District201506, Shanghai, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

Residual Current Units
5SM9...-0KK, 5SM9...-0KN, 5SM9...-6KK, 5SM9...-6KN, 5SM9...-6KK01;See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T16917.1-2014;GB/T16917.22-2008

TYPE OF CERTIFICATION SCHEMES

Type testing of product + initial factory inspection + follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462143-2019 .

Valid from: Jul.10,2020 **Valid until:** Nov.15,2023

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

CHINA QUALITY CERTIFICATION CENTRE 中国质量认证中心

President: _____
Lu Mei

CHINA QUALITY CERTIFICATION CENTRE

Section 9,No.188,Nansihuan Xilu, Beijing 100070 P.R.China
http://www.cqc.com.cn

C 0261760

产品认证证书

纸号：261760

附录：

证书编号：CQC2013010307662965

5SM9...-0KK,5SM9...-0KN,5SM9...-6KK,5SM9...-6KN,5SM9...-6KK01

5SM9...-0KK:

Ue:AC 230V/400V(2P),AC400V(3P,4P) ;

2P:I△n:10mA /30mA /100mA/300mA,In:≤16A, ≤25A, ≤40A, ≤63A;

3P,4P:I△n:30mA /100mA/300mA,In: ≤40A, ≤63A;

额定剩余动作类型:AC Type;

额定剩余动作类型:电子式;

2P,3P,4P;

5SM9...-0KN:

Ue:AC 230V;

I△n :10mA /30mA/100mA/300mA ,In:≤16A, ≤40A, ≤63A;

额定剩余动作类型:AC Type;

额定剩余动作类型:电子式;

2P;

5SM9...-6KK:

Ue:AC 230V/400V(2P),AC400V(3P,4P) ;

2P:I△n:10mA /30mA/300mA,In:≤16A, ≤40A, ≤63A;

3P,4P:I△n:30mA/300mA,In:≤40A, ≤63A;

额定剩余动作类型:A Type;

额定剩余动作类型:电子式;

2P,3P,4P;

5SM9...-6KN:

Ue:AC 230V;

I△n : 30mA ,In:≤40A, ≤63A;

额定剩余动作类型:A Type;

额定剩余动作类型:电子式;

注：此附录与证书同时使用时有效。

主任：

CHINA QUALITY CERTIFICATION CENTRE 中国质量认证中心

中国质量认证中心

中国．北京．南四环西路 188 号 9 区 100070

http://www.cqc.com.cn

产品认证证书

附录:

证书编号: CQC2013010307662965

纸号: 261760

2P;

5SM9...-6KK01:
Ue:AC 230V/400V(2P) ;
2P:I△n:30mA,In:≤40A, ≤63A;
额定剩余动作类型:A(K) Type;
额定剩余动作类型:电子式;
2P;
I△m:6kA
适用于隔离用

注: 此附录与证书同时使用时有效。

主任:

中国质量认证中心

中国 . 北京 . 南四环西路 188 号 9区 100070
http://www.cqc.com.cn

产品认证证书

纸号：261760

附录：

证书编号：CQC2013010307662965

配用的小型断路器:
CCC 证书编号:2013010307622233
5SY6...-.CC,5SY4...-.CC,5SY4...-.CC11
Ue: AC230V(1P+N); AC400V(2P,3P ,3P+N ,4P);
In:
C,D 型:
0.3A,0.5A,1A,1.6A,2A,3A,4A,6A,8A,10A,13A,16A,20A,25A ,32A ,40A ,50A, 63A;
B 型: 1A, 2A, 3A, 4A, 6A, 10A, 16A, 20A, 25A , 32A, 40A, 50A, 63A;
瞬时脱扣类型:B,C,D 型;
Ics=6kA(5SY6...-.CC), Ics=7.5kA(5SY4...-.CC,5SY4...-.CC11);
Icn=6kA(5SY6...-.CC), Icn=10kA(5SY4...-.CC,5SY4...-.CC11);
2P, 3P, 4P, 1P+N, 3P+N

CCC 证书编号: 2005010307159866
5SJ4...-6CC20, 5SJ4...-7CC20, 5SJ4...-8CC20
Ue: 230V（1P+N）, 400V（2P、3P、3P+N、4P）;
In: 0.3A, 0.5A, 1A, 1.6A, 2A, 3A, 4A, 6A, 8A, 10A, 13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A; (5SJ4...-7CC20, 5SJ4...-8CC20);
In: 1A, 2A, 3A, 4A, 6A, 10A, 16A, 20A, 25A, 32A, 40A, 50A, 63A; (5SJ4...-6CC20);
瞬时脱扣类型: B 型, C 型, D 型;
Ics=7500A;Icn=10000A;
1P+N , 2P, 3P, 3P+N, 4P(5SJ4...-7CC20,5SJ4...-8CC20)
2P, 3P, 4P(5SJ4...-6CC20)

CCC 证书编号:2004010307129231
5SJ6...7CC20,5SJ6...8CC20, 5SJ0...7CC20, 5SJ0...8CC20,5SJ6...7CR,5SJ6...8CR
5SJ6...7CC20,5SJ6...8CC20, 5SJ0...7CC20, 5SJ0...8CC20:
Ue: AC230V(1P+N), AC400V(2P, 3P, 3P+N, 4P);
In:0.3A,0.5A,1A,1.6A,2A,3A,4A,6A,8A,10A,13A,16A,20A,25A,32A,40A,50A, 63A;

注：此附录与证书同时使用时有效。

主任：

中国质量认证中心

中国．北京．南四环西路 188 号 9 区 100070
http://www.cqc.com.cn

产品认证证书

附录：

证书编号：CQC2013010307662965

瞬时脱扣类型:C 型, D 型;
Icn=Ics:6kA;
1P+N(N 极可开闭), 2P, 3P, 3P+N(N 极可开闭), 4P
5SJ6...7CR:
Ue: AC230V(1P+N),AC400V(2P,3P,4P);
In: 0.5A,1A, 2A,4A, 6A,32A,40A,50A,63A(1P,2P,1P+N);
In: 0.5A,1A, 2A,4A, 6A,25A,32A,40A,50A,63A(3P);
In:0.5A,1A,2A,4A,6A,10A,13A,16A,20A, 25A,32A,40A,50A,63A(4P);
瞬时脱扣类型:C 型;
Icn=Ics:6kA;
1P+N(N 极可开闭), 2P, 3P, 4P
5SJ6...8CR:
Ue: AC400V(2P,3P,4P);
In: 0.5A,1A,2A,4A,6A,10A,13A,16A,20A, 25A,32A,40A,50A,63A
瞬时脱扣类型:D 型;
Icn=Ics:6kA;
2P, 3P, 4P

注：此附录与证书同时使用时有效。

主任：

中国质量认证中心

中国．北京．南四环西路 188 号 9 区 100070
http://www.cqc.com.cn

产品认证证书


附录：

证书编号：CQC2013010307662965

纸号：261760

型号的解释：

5SM9 121-6KK



注：此附录与证书同时使用时有效。

主任：

中国质量认证中心

中国．北京．南四环西路 188 号 9区 100070

http://www.cqc.com.cn